

Glystantin®_FC_G20®_ELECTRIFIED®

分析证书

Pruefmerkmal Spec. characteristic	Pruefmethode Test method	Pruefergebnis Test result	Pruefspezifikation Specification
Lieferform Appearance	visuell visual	entspricht fulfilled	farblose, klare Lösung colorless, clear liquid
pH-Wert original pH-Value undiluted	ASTM D 1287	5,5	4,9 - 6,8
Wassergehalt Water content	DIN 51 777 Teil 1 part 1	49,7 Gew.-% Wt.-%	48,0 - 52,0 Gew.-% Wt.-%
Dichte, 20 Grad C Density, 20 deg C	DIN 51 757 Verf.3 proc.3	1,065 g/mL	1,050 - 1,070 g/mL
Elektr. Leitfähigkeit, 25°C Electr. conductivity, 25deg	ASTM D 1125-95	0,8 µS/cm	max. 5,0 µS/cm

⚠ 特别说明!

本 Glystantin®_FC_G20®_ELECTRIFIED®分析证书数据真实有效, 目的是使消费者了解产品之用。随货提供同批号的 Certificate of Analysis。

关于 Glystantin®_FC_G20®_ELECTRIFIED® 产品的更多信息, 请浏览:
http://www.jncrd.com/2020/BASF_0725/124.html



济南诚润达贸易有限公司
138 6916 5207
info@chengrunda.com
www.jncrd.com

